

Tratament chimic MIROS NEPLACUT BOILERE, STOCATOARE, REZERVOARE APA



CHIMIA
INSTALATIEI
TERMICE

Probleme tratate: MICROORGANISME

Materiale: OTEL / INOX / PLASTIC

Varianta 1 – BOILERE, STOCATOARE – fluid termic, apa de consum

CHECK SERVICE




Verificare parametrului fluid

CLEANEX SANIT



Solutie 10-15%
(cca 10kg / 100l apa)



Recirculare: 30-50 min
Eliminare solutie si clatire
cu apa din abundenta

BIO TEST



Verificare rezultate
(cca. 24-48 ore)

Varianta 2 – REZERVOARE DE APA, FANTANI – apa de consum, apa potabila

CHECK SERVICE



Verificare parametrului fluid

BICLOSOL



Cca 2-3 tablete / 1000l apa)

BIO TEST



Verificare rezultate
(cca. 24-48 ore)