

Tratament chimic: CONSUM RIDICAT, LIPSA APA CALDA, ZGOMOT BOILERE INOX, SCHIMBATOARE IN PLACI INDUSTRIALE



CHIMIA
INSTALATIEI
TERMICE

Probleme tratate: **CALCAR, OXIZI, IMPURITATI MECANICE**

Materiale: **INOX / ALUMINIU**

CHECK SERVICE




Verificare parametrul fluid

CLEANEX Inox-AI



Solutie 20-25%
(cca 2.5kg / 10l apa)



Recirculare: 30-50 min




Monitorizare: pH<3

NEUTRALIZER ALCALIN



Solutie 1-4%
(cca 100g / 10l apa)



Recirculare: 5-10 min

APA DEMINERALIZATA



Clatire instalatie pana la pH 6.5-7.5
Incarcare cu apa demineralizata

INSTAL PROTECT



Dozare 1-2%
(cca. 1kg / 100l)