

# Tratament chimic: CALORIFERE PARTIAL RECI CALORIFERE OTEL/FONTA, INSTALATII TEAVA NEAGRA



CHIMIA  
INSTALATIEI  
TERMICE

Probleme tratate: **MAGNETITA, NAMOL, IMPURITATI MECANICE**

Materiale: **OTEL / FONTA**

## CHECK SERVICE




Verificare parametrul fluid

## CLEANEX INSTAL



Solutie 5-15%  
(cca 5kg / 100l apa)



Recirculare: 15-20 min  
(fiecare circuit/calorifer)




Monitorizare: pH>10

## NEUTRALYZER ACID



Solutie 1-4%  
(cca 2-3kg / 100l apa )



Recirculare: 5-10 min  
(fiecare circuit/calorifer)

## APA DEMINERALIZATA



Clatire instalatie pana la pH 6.5-7.5  
Incarcare cu apa demineralizata

## INSTAL PROTECT



Dozare 1-2%  
(cca. 1kg / 100l)